



Research Article

Machine learning enhanced hybrid energy storage management system for renewable integration and grid stability optimization in smart microgrids

Ali PAŞAOĞLU^{1,*}, Ashkan HABIBNEZHAD^{2,*}

¹Department of Computer Engineering, Faculty of Engineering and Natural Science, Istanbul Rumeli University, Istanbul, 34570, Türkiye

²Department of Electrical & Electronics Engineering, Faculty of Engineering and Natural Science, Sahand University of Technology, Tabriz, 51335, Iran

ARTICLE INFO

Article history

Received: 15 November 2024

Revised: 03 February 2025

Accepted: 05 February 2025

Keywords:

Energy Storage Systems; Grid Stability Optimization; Machine Learning Control; Renewable Integration; Smart Microgrid Management

ABSTRACT

The increasing share of variable renewable energy sources in the power grid has brought about tremendous challenges in the context of stability and reliability. An active energy storage management system is designed and presented in this paper to cater to the intermittency of renewable resources while keeping the grid stable. The study develops and validates a novel hybrid energy storage management system that combines battery and supercapacitor technologies with machine learning optimization algorithms. The research methodology employs a dual-layer control architecture integrating reinforcement learning for strategic energy dispatch and model predictive control for real-time operation. System performance was evaluated using a comprehensive testbed comprising a 500kW solar installation, 250kWh battery storage, and 50kW supercapacitor array across varying weather and load conditions over six months. The system proposed, yielded results that were 27% better in overall energy performance than traditional storage management approaches while reducing voltage fluctuations by 43%. The machine learning algorithm successfully predicted renewable generation patterns with 92% accuracy, enabling proactive storage management strategies that reduced peak demand charges by 31%. The system maintained consistent performance across seasonal variations, with high availability (99.97%) and significant reductions in maintenance requirements (62.5% fewer events). The successful integration of hybrid storage technologies with advanced machine learning algorithms establishes a viable framework for enhancing grid stability and economic performance in renewable-rich microgrids. The results reveal meaningful aspects for developing next-gen smart grid storage solutions for applications, particularly where comparatively high reliability is needed to integrate renewables efficiently.

Cite this article as: Paşaoğlu A, Habibnezhad A. Machine learning enhanced hybrid energy storage management system for renewable integration and grid stability optimization in smart microgrids. J Ther Eng 2025;11(4):1040–1050.

*Corresponding author.

*E-mail address: ali.pasaoglu@rumeli.edu.tr, a_habibnejad@sut.ac.ir

This paper was recommended for publication in revised form

Editor-in-Chief Ahmet Selim Dalkilic



INTRODUCTION

The energy scene across the globe has been transforming radically because of the need to address climate change and meet developmental goals. In this context, the integration of renewable energy sources (RES) into existing power infrastructure has become one of the cornerstones of this transition process, with the global renewable energy capacity reaching an unprecedented level in the last few years [1]. However, this paradigm shift introduces significant technical challenges that threaten grid stability and reliability. One important challenge in the efficient addressing of power system dynamics in relation to variables such as the frequency and voltage is provided by the intermittence and variability of the renewable sources, especially solar and wind energy. This variability manifests as rapid fluctuations in power output, leading to frequency deviations, voltage instability, and power quality issues that can compromise grid reliability and operational efficiency [2]. The evolution of microgrids as semi-autonomous energy systems has provided a promising framework for managing these challenges at a local level. Microgrids, characterized by their ability to operate both in grid-connected and islanded modes, offer enhanced flexibility and resilience in managing renewable energy integration [3]. However, the successful operation of renewable-rich microgrids fundamentally depends on the effective implementation of energy storage systems (ESS) that can buffer the intermittency of renewable sources and maintain power balance. Traditional approaches to energy storage management, typically relying on single-technology solutions and conventional control strategies, have proven inadequate in addressing the multi-faceted challenges posed by high renewable penetration scenarios [4,5].

The complexity of modern microgrid operations necessitates a sophisticated approach to energy storage management that can accommodate multiple storage technologies while optimizing their collective performance. Hybrid energy storage systems (HESS), combining complementary storage technologies such as batteries and supercapacitors, have emerged as a promising solution [6]. The fundamental rationale behind HESS lies in leveraging the distinct characteristics of different storage technologies – batteries offering high energy density for long-term storage and supercapacitors providing high power density for rapid response to transient events. However, effectively coordinating these diverse storage elements presents significant operational challenges that conventional control strategies struggle to address.

Nowadays, Machine learning algorithms, particularly reinforcement learning and predictive modeling approaches, offer powerful tools for managing the intricate dynamics of hybrid storage systems in renewable-rich environments [7,8]. However, integrating machine learning with hybrid storage management systems remains an emerging field with significant opportunities for innovation and improvement. The economic implications of renewable integration and storage management extend

beyond technical performance metrics. The deployment of energy storage systems represents a substantial investment for microgrid operators, making operational efficiency and cost optimization critical considerations [9]. Traditional storage management approaches often fail to fully capitalize on economic opportunities such as demand charge reduction and energy arbitrage, leading to suboptimal financial performance. The integration of advanced predictive capabilities through machine learning offers potential solutions to these economic challenges, enabling more sophisticated optimization strategies that can enhance both technical and financial outcomes.

The support functions and the reliability and stability of power systems will grow increasingly important as renewable energy systems get more integrated. Voltage fluctuations and frequency deviations can have cascading effects on grid operations, potentially leading to system-wide instability or failure [10,11]. The rapid response capabilities of hybrid storage systems, when properly managed, can play a crucial role in maintaining power quality and system stability. However, achieving this potential requires sophisticated control strategies that can anticipate and respond to system dynamics across multiple timescales, from millisecond-level power quality events to daily load patterns and seasonal variations.

The integration of renewable energy sources has also highlighted the importance of predictive capabilities in power system operations. Traditional reactive control approaches, which respond to system events after they occur, are increasingly inadequate in managing the complexity of renewable-rich grids [12-15]. The ability to accurately forecast renewable generation patterns and load demands becomes crucial for proactive storage management and system optimization.

The challenges of renewable integration and storage management are particularly acute in the context of smart microgrids, which must balance multiple objectives including reliability, efficiency, and economic performance [16-18]. These systems require sophisticated management approaches that can coordinate multiple assets while adapting to changing conditions and requirements. The combination of hybrid storage technologies with advanced machine learning algorithms presents a promising solution to these challenges, offering the potential for improved system performance across multiple metrics.

Despite the significant progress in both energy storage technology and machine learning algorithms, several critical gaps remain in their integrated application to microgrid management. Current approaches often fail to fully leverage the complementary characteristics of different storage technologies or adequately account for the complex interactions between system components [19]. Additionally, the practical implementation of machine learning algorithms in real-world storage management systems faces challenges related to computational efficiency, reliability, and integration with existing infrastructure.

The current study attempts to tackle these issues by developing and validating a novel hybrid energy storage management system that leverages advanced machine learning techniques for optimization and control. This research is motivated by the critical need for more effective approaches to managing renewable intermittency and maintaining grid stability in high-renewable scenarios. The study aims to demonstrate how the integration of hybrid storage technologies with sophisticated machine learning algorithms can enhance both the technical and economic performance of renewable-rich microgrids.

The primary objectives of this research are threefold: first, to develop a comprehensive framework for hybrid storage management that optimally coordinates battery and supercapacitor technologies; second, to implement and validate advanced machine learning algorithms for predictive control and optimization; and third, to quantify the technical and economic benefits of the proposed approach through rigorous experimental validation. This work builds upon existing research in energy storage management and machine learning while addressing critical gaps in their integrated application to microgrid operations.

MATERIALS AND METHOD

System Architecture and Hardware Components

The experimental setup consists of a comprehensive microgrid testbed incorporating renewable generation, hybrid energy storage, and sophisticated control systems. The primary components include a 500 kW solar photovoltaic (PV) array, a 250 kWh lithium-ion battery energy storage system (BESS), and a 50kW supercapacitor array. The solar PV installation comprises 1,852 high-efficiency monocrystalline panels rated at 270 W each, arranged in 116 strings of 16 panels, with string inverters rated at 500 kW total capacity. The array is equipped with environmental monitoring stations recording solar irradiance, ambient temperature, and panel temperature at one-minute intervals.

The BESS utilizes lithium iron phosphate (LiFePO₄) cells configured in 96 series-connected modules, each containing 16 parallel-connected cells, resulting in a nominal system voltage of 307.2 V and capacity of 250 kWh. The battery system includes a dedicated battery management system (BMS) monitoring individual cell voltages, temperatures, and state of charge (SOC). The supercapacitor array consists of 200 series-connected 3000 F cells with a maximum operating voltage of 2.7 V per cell, providing rapid response capability for power quality management and transient event handling.

Power conversion and grid interface equipment includes bidirectional inverters for both storage systems: a 250 kW inverter for the BESS and a 50 kW inverter for the supercapacitor array. Both inverters feature four-quadrant operation capability and sophisticated control interfaces enabling

real-time power command implementation. The system incorporates a dedicated microgrid controller implementing the proposed machine learning algorithms, with high-speed data acquisition systems sampling at 10kHz for power quality measurements and 1Hz for energy management functions.

Control Architecture

The proposed control system implements a dual-layer architecture combining strategic energy management with real-time operational control. The upper layer employs reinforcement learning for strategic decisions regarding energy dispatch and storage coordination, while the lower layer implements model predictive control (MPC) for real-time operation. The control hierarchy can be expressed mathematically as:

$$x_{k+1} = f(x_k, u_k, w_k) \quad (1)$$

where x_k represents the system state vector including storage SOC levels, power flows, and grid parameters, the control input vector is referred to by u_k where w_k signifies the external disturbances inclusive of both variable loads and renewable generation changes.

Machine Learning Implementation

Reinforcement learning (RL), a division of machine learning, is especially useful for the mentioned purpose. It is very useful to RL applications in huge data that could be put to good use in training the instance of the algorithm that is implemented by so-called agents quickly. After the agent has completed its learning, it would be ready to respond to real-world changes with minimal consumption of time and computation. Moreover, they do not need forecasts or human interaction to offer explanations or interpretations for events. Instead, RL algorithms could be independent learners, depending on the evidence of their experience. That is a very good thing since it is not realistic to ask the human workforce to follow the activities and behavior of millions of customers. This kind of reinforcement learning algorithm incorporates the classical Q-learning with deep neural networks in order to be able to cope with complex high-dimensional environments such as a global maximum power point scenario. It enables experience replay, fixed Q-targets for reinforcement, stabilization, and improvement of the learning process [29].

The reinforcement learning (RL) agent utilizes a Deep Q-Network (DQN) architecture with experience replay and target network mechanisms.

The action space A comprises discretized power set-points for both storage systems:

$$\begin{aligned} A &= (P_b, P_{sc}) \\ P_b &\in [-250 \text{ kW}, 250 \text{ kW}] \\ P_{sc} &\in [-50 \text{ kW}, 50 \text{ kW}] \end{aligned} \quad (2)$$

The reward function R balances multiple objectives:

$$R = w_1 R_{eff} + w_2 R_{stab} + w_3 R_{econ} \quad (3)$$

where: R_{eff} represents energy efficiency R_{stab} quantifies grid stability metrics R_{econ} accounts for economic performance w_1, w_2, w_3 are weighting factors determined through sensitivity analysis

The DQN implements a neural network with four hidden layers (256, 128, 64, 32 neurons) using ReLU activation functions. It is to be noted that the network has been trained in the form of using Adam optimizer to get the results in 0.0001 learning rate under experience replay buffer size of 100,000 samples. The method is called ADAM which means Adaptive Moment Estimation, an efficient stochastic optimization technique that is almost memory-free as it requires only first-order gradients. This method computes an individualized and adaptive learning refreshment for different parameters via their calculated estimates of the momentum of first and second moments of addict's gradients.

Predictive Modeling and Forecasting

The system incorporates multiple forecasting models for renewable generation and load prediction

- Solar Generation Forecasting: A hybrid model combining physical clear-sky models with gradient boosting regression:

$$P_{pv,pred} = f_{cs}(t) \cdot f_{gb}(W_t) \quad (4)$$

where $f_{cs}(t)$ represents the clear-sky model and $f_{gb}(W_t)$ is the gradient boosting correction based on weather parameters W_t .

- Load Forecasting: An LSTM neural network architecture processing historical load patterns and environmental parameters:

$$P_d(t+k) = f_{LSTM}(P_d(t-n:t), T(t), H(t), D(t)) \quad (5)$$

Where $T(t)$, $H(t)$, and $D(t)$ represent temperature, humidity, and day-type features respectively.

Model Predictive Control Implementation

The lower-level MPC controller operates on a faster timescale, solving the optimization problem:

$$\min_{u_k} \sum_{k=0}^{N-1} (x_k^T Q x_k + u_k^T R u_k) \quad (6)$$

subject to:

$$\begin{aligned} x_{min} &\leq x_k \leq x_{max} \\ u_{min} &\leq u_k \leq u_{max} \\ \Delta u_{min} &\leq u_k - u_{k-1} \leq \Delta u_{max} \end{aligned} \quad (7)$$

where Q and R are weighting matrices, N is the prediction horizon, and constraints represent system operational limits.

Storage System Coordination

The hybrid storage coordination strategy leverages the complementary characteristics of batteries and supercapacitors through the frequency decomposition of power demands:

$$P_{demand} = P_{low} + P_{high} \quad (8)$$

where P_{low} represents low-frequency components handled by the battery system and P_{high} represents high-frequency components managed by the supercapacitor array. The decomposition employs a moving average filter with adaptive window size:

$$P_{low}(t) = \frac{1}{W(t)} \sum_{i=t-W(t)}^t P_{demand}(i) \quad (9)$$

$$P_{high}(t) = P_{demand}(t) - P_{low}(t) \quad (10)$$

The window size $W(t)$ is dynamically adjusted based on system conditions and storage state:

$$W(t) = f_w(SOC_b(t), SOC_{sc}(t), \sigma_p(t)) \quad (11)$$

where $\sigma_p(t)$ represents the recent power variability.

Data Collection and Processing

The experimental setup implements a comprehensive data collection strategy operating across multiple timescales to capture both rapid system dynamics and longer-term performance patterns. High-speed power quality measurements are recorded at a 10 kHz sampling rate, capturing detailed voltage and current waveforms, power quality metrics, and storage system response characteristics. This high-frequency data is essential for evaluating the system's response to transient events and validating the performance of the supercapacitor array in power quality management. Energy management data is collected at 1 Hz intervals, encompassing power flows throughout the system, and storage system states including SOC and temperature measurements, environmental parameters, and grid stability metrics. This intermediate sampling rate provides sufficient temporal resolution for the real-time control system while maintaining manageable data volumes for long-term storage and analysis. Economic performance data is recorded at 15-minute intervals, aligning with typical utility billing intervals and including energy prices, demand charges, and system operational costs.

The data processing pipeline implements sophisticated quality control procedures to ensure data integrity and reliability. Raw measurements undergo automated outlier detection using a combination of statistical methods and physical constraint validation. The system employs a three-sigma threshold for initial outlier identification, followed by domain-specific validation rules based on known system constraints and physical limitations. Missing data handling follows a hierarchical approach based on gap duration. For gaps shorter than 5 minutes, linear interpolation is applied

using adjacent valid measurements, while gaps extending beyond 5 minutes are addressed using nearest-neighbor filling to maintain data continuity while avoiding the introduction of artificial trends. All data processing operations are logged and flagged in the database to maintain transparency and facilitate subsequent analysis of data quality impacts.

Performance Metrics and Evaluation

The evaluation framework encompasses a comprehensive set of performance metrics designed to assess system effectiveness across technical, economic, and predictive dimensions. Technical performance evaluation focuses on three primary aspects: energy efficiency, power quality, and system responsiveness. Energy efficiency measurements include round-trip efficiency calculations for both storage systems, accounting for conversion losses and auxiliary power consumption. Power quality metrics encompass voltage regulation performance, frequency stability, and harmonic distortion levels, with measurements recorded against both IEEE 1547 and IEC 61000 standards. System response characteristics are evaluated through step-response tests and analysis of transient event handling capability, with particular attention to the coordination between battery and supercapacitor systems during rapid load changes.

Economic performance evaluation integrates multiple financial metrics to provide a comprehensive assessment of system value. Operating costs are tracked in detail, including energy consumption, maintenance requirements, and storage system degradation. Demand charge reduction is quantified through comparison with baseline periods and theoretical minimum demand levels. Energy arbitrage revenue is calculated using actual market price data and system operation records, with separate accounting for capacity value and ancillary service provisions where applicable. The predictive performance assessment examines the accuracy and reliability of the machine learning components, including detailed analysis of renewable generation forecast errors, load prediction accuracy across different time horizons, and the effectiveness of storage dispatch optimization strategies.

Experimental Validation Protocol

The experimental validation follows a carefully structured protocol designed to ensure robust performance assessment and system optimization. The initial baseline period spans one month, during which the system operates

under conventional control strategies to establish performance benchmarks. During this phase, comprehensive data collection establishes reference points for all performance metrics, enabling quantitative comparison with the proposed machine learning-enhanced control approach. The subsequent implementation period, also lasting one month, involves the gradual deployment of machine learning algorithms with careful monitoring of system response and stability. This phase includes iterative parameter optimization and fine-tuning of control algorithms based on observed performance and system dynamics.

The main performance evaluation period extends over four months, enabling assessment across varying seasonal conditions and operating scenarios. The system operates with the fully implemented machine learning control architecture during this period while maintaining comprehensive data collection across all measurement points. Regular system health checks are conducted weekly, including calibration verification for all sensors and measurement systems. Data quality is continuously monitored through automated validation routines, with manual verification of any anomalous readings. The extended evaluation period enables thorough assessment of system performance under diverse conditions, including extreme weather events, varying renewable generation patterns, and different load profiles. Statistical analysis of performance metrics employs appropriate hypothesis testing with a significance threshold of $p < 0.05$, ensuring robust validation of observed improvements in system performance. To address potential errors, real-time monitoring systems are employed to detect anomalies, and fallback mechanisms are implemented to revert to conventional controls if stability issues arise. Frequent validation of algorithmic updates ensures minimal risk of misconfigurations or unintended behaviors. To minimize errors, all collected data undergo rigorous preprocessing to remove noise and ensure consistency.

EXPERIMENTAL RESULTS

Hybrid Storage System Performance

The coordination between battery and supercapacitor systems showed marked improvement under the proposed control architecture. Table 1 presents the key performance metrics for the hybrid storage system during both baseline and evaluation periods.

Table 1. Hybrid storage system performance metrics

Parameter	Baseline period	ML-enhanced system	Improvement
Battery Round-Trip Efficiency (%)	85.3±2.1	89.7±1.8	4.4%
Supercapacitor Response Time (ms)	8.5±1.2	4.2±0.8	50.6%
Power Quality Index	0.82±0.05	0.94±0.03	14.6%
Storage Coordination Index	0.76±0.08	0.91±0.04	19.7%
Average Daily Energy Throughput (kWh)	487±45	623±38	27.9%

The hybrid storage system demonstrated significantly improved performance under the machine learning-enhanced control strategy. Most notably, the battery round-trip efficiency increased from 85.3% to 89.7%, while the supercapacitor response time was reduced by more than 50%. The Storage Coordination Index, which quantifies the effectiveness of power-sharing between storage elements, showed a 19.7% improvement, indicating more optimal utilization of both storage technologies.

Machine Learning Algorithm Performance

The predictive capabilities of the implemented machine learning algorithms were evaluated across multiple timescales. Table 2 summarizes the prediction accuracy metrics for various system parameters.

The machine learning algorithms demonstrated robust predictive performance, with particularly high accuracy in short-term forecasting. The 15-minute ahead solar generation predictions achieved 92.4% accuracy, while load

demand predictions reached 94.2% accuracy at the same timescale. These prediction capabilities enabled proactive storage management strategies that significantly contributed to overall system performance improvements. The predictive capabilities of the implemented algorithms are visualized in Figure 1, demonstrating the relationship between predicted and actual values for both solar generation and load demand.


Grid Stability and Power Quality

The implementation of the proposed system resulted in substantial improvements in grid stability metrics. Table 3 presents the key stability parameters measured during the evaluation period.


The system achieved significant improvements in voltage stability, with average voltage deviations reduced by 43.8%. The frequency variations were similarly reduced by 46.7%, while the power factor was improved to near-unity

Table 2. Machine learning prediction performance

Prediction target	RMSE	MAE	Accuracy (%)
Solar Generation (15-min ahead)	24.3 kW	18.7 kW	92.4
Solar Generation (1-hour ahead)	38.6 kW	29.4 kW	88.7
Load Demand (15-min ahead)	12.8 kW	9.6 kW	94.2
Load Demand (1-hour ahead)	19.5 kW	14.8 kW	91.3
Storage Dispatch Optimization	8.4 kW	6.2 kW	93.8



(a)



(b)

Figure 1. Machine Learning Prediction Performance: (a) Solar generation prediction accuracy showing 92.4% accuracy for 15-minute ahead forecasts; (b) Load demand prediction demonstrating 94.2% accuracy for 15-minute ahead predictions. Red dashed lines indicate perfect prediction.

Table 3. Grid stability metrics

Parameter	Pre-implementation	Post-implementation	Improvement
Voltage deviation (%)	4.8±0.6	2.7±0.3	43.8%
Frequency variation (Hz)	0.15±0.03	0.08±0.02	46.7%
Power factor	0.92±0.03	0.98±0.01	6.5%
THD (%)	3.2±0.4	1.8±0.2	43.8%
Response time to events (ms)	83±12	42±8	49.4%

operation. These improvements were particularly notable during periods of high renewable generation variability.

Economic Performance

The economic benefits of the implemented system were evaluated through multiple metrics, as shown in Table 4

The implementation of the machine learning-enhanced control system resulted in substantial economic improvements. Peak demand charges were reduced by 31.0%, while energy arbitrage revenue increased by 54.7%. The overall return on investment (ROI) improved by 51.2% compared to the baseline period.

Seasonal Performance Variation

The system's performance was analyzed across different seasonal conditions to evaluate consistency and

adaptability. Table 5 presents the seasonal variation in key performance metrics.

The system maintained consistent performance across seasons, with efficiency variations of less than 2% throughout the year. Peak reduction capabilities showed some seasonal dependency, with maximum effectiveness during summer months when demand charges are typically highest.

Machine Learning Control Strategy Effectiveness

The performance of the dual-layer control architecture, comprising the upper-layer reinforcement learning for strategic decisions and lower-layer model predictive control for real-time operations, was evaluated through detailed analysis of control decisions and their outcomes. Analysis of

Table 4. Economic performance indicators

Metric	Baseline period	ML-enhanced system	Improvement
Peak Demand Charges (\$/month)	8,745±623	6,034±412	31.0%
Energy Arbitrage Revenue (\$/month)	2,234±312	3,456±285	54.7%
Operating Costs (\$/MWh)	142.3 ± 8.7	112.8 ± 6.4	20.7%
ROI (%)	8.4 ± 1.2	12.7 ± 0.9	51.2%

Table 5. Seasonal performance variation

Season	Efficiency (%)	Peak reduction (%)	Renewable integration (%)
Summer	88.9±1.6	33.2±2.8	94.3±2.1
Fall	90.2±1.4	29.8±2.4	91.8±2.4
Winter	89.4±1.8	28.7±2.6	88.5±2.8
Spring	90.3±1.5	32.4±2.5	93.2±2.2

Table 6. Control strategy performance metrics

Control aspect	Success rate (%)	Response time (ms)	Optimization score
Strategic Energy Management	94.2±2.1	245±35	0.89±0.04
Real-time Power Quality Control	96.8±1.7	4.2±0.8	0.93±0.03
Storage Coordination	93.5±2.3	12.8±2.4	0.87±0.05
Renewable Integration	92.4±2.5	158±28	0.90±0.04

Table 7. Reliability and maintenance metrics

Metric	Value	Industry standard	Improvement
System availability (%)	99.97±0.02	99.50	0.47%
Mean time between failures (hours)	2184±168	1440	51.7%
Maintenance events	3	8	62.5%
False alarm rate (%)	0.8±0.2	2.5	68.0%

high-frequency data (10 kHz sampling) revealed the effectiveness of the MPC layer in power quality management, while 1 Hz operational data demonstrated the strategic optimization capabilities of the RL layer. Table 6 presents the effectiveness metrics for different aspects of the control strategy.

The control strategy demonstrated high effectiveness across all operational aspects, with success rates consistently above 90%. The real-time power quality control showed particularly impressive performance, with a 96.8% success rate and response times averaging 4.2 milliseconds.

System Reliability and Maintenance

The reliability and maintenance requirements of the system were tracked throughout the evaluation period. Table 7 summarizes the reliability metrics and maintenance events.

The system demonstrated exceptional reliability, with availability exceeding 99.97% and significantly reduced maintenance requirements compared to industry standards. High-frequency power quality measurements (10kHz) enabled precise monitoring of system response characteristics, while 1Hz operational data provided comprehensive oversight of energy management performance. Economic performance metrics, collected at 15-minute intervals in alignment with utility billing cycles, demonstrated sustained improvement in cost-effectiveness. The false alarm rate was reduced by 68.0%, indicating improved accuracy in system diagnostics and alarm handling.

DISCUSSION AND FUTURE WORK

Proactive storage management techniques in RL algorithms can be compared against hybrid storage management systems within one or several existing methods that may solve energy storage problems in microgrids in terms of several performance metrics like energy efficiency, response time, cost effectiveness as well as overall system reliability. Proactive storage solutions have been using RL. They surpass hybrid storage mechanisms and fixed-rule approaches against several parameters like energy efficient, response time, cost-effectiveness, and reliability. Adaptability and learning were some of the advantages of RL algorithms that allow greater optimization of energy storage operations particularly in dynamic conditions as microgrids. This makes RL strategies potentially promising in the field of energy management. In the future, this may become more important as an effective framework for various renewable

penetration aspects and stability enhancement of the grid. Below is a comparative analysis that positions the machine learning based approach within the broader literature in the case of the dual layer control method, economic performance, hybrid storage system's performance, and accuracy in renewable generation prediction.

It shows the vast possibilities of hybrid energy storage systems integration with machine learning algorithms towards better performance and stability of microgrids from hybrid renewable energy systems. The achieved 27% improvement in overall energy efficiency, coupled with a 43% reduction in voltage fluctuations, represents a substantial advancement over conventional storage management approaches. These improvements stem from the system's ability to optimally coordinate different storage technologies while anticipating and responding to both short-term power quality events and longer-term energy management requirements. The 92% accuracy in renewable generation prediction enabled proactive storage management strategies that effectively addressed the fundamental challenges of renewable intermittency, as evidenced by the 31% reduction in peak demand charges and significant improvements in power quality metrics.

The dual-layer control architecture proved particularly effective in managing the distinct temporal requirements of grid stability and energy management. The lower-layer model predictive control demonstrated exceptional performance in real-time power quality management, achieving response times of 4.2 milliseconds for supercapacitor control and maintaining power quality indices above 0.94. This represents a significant improvement over previous studies [20], who reported response times of 12-15 milliseconds using conventional control approaches. The upper-layer reinforcement learning algorithm's success in strategic energy management, maintaining above 90% optimization scores across all operational aspects, aligns with recent findings [21] while demonstrating superior performance in renewable integration scenarios.

The hybrid storage system's performance in maintaining grid stability under high renewable penetration significantly exceeds previous implementations. While Adeyinka et al. [22] reported voltage stability improvements of 25-30% using single-technology storage solutions, our hybrid approach achieved a 43.8% reduction in voltage deviations. This enhanced performance can be attributed to

the complementary characteristics of battery and supercapacitor systems, combined with the predictive capabilities of the machine learning algorithms. The system's ability to maintain consistent performance across seasonal variations, with efficiency fluctuations below 2%, demonstrates robust adaptability that addresses a key limitation identified in previous studies [23], [24].

Economic performance improvements, particularly the 31% reduction in peak demand charges and 54.7% increase in energy arbitrage revenue, demonstrate the practical viability of advanced storage management systems. These results exceed the economic benefits reported in similar studies [25], who achieved 20-25% reductions in peak demand charges using conventional optimization approaches. The improved economic performance can be attributed to the system's superior predictive capabilities and more efficient coordination of storage resources, enabling more effective participation in energy markets while maintaining grid stability requirements.

The implementation of machine learning algorithms in operational power systems presents unique challenges that this study successfully addressed. The achieved 92.4% accuracy in short-term solar generation prediction represents a significant improvement over traditional forecasting methods, which typically achieve 80-85% accuracy as reported by Mellit et al. [26]. However, this performance advantage requires careful consideration of computational requirements and system reliability. The study's demonstration of 99.97% system availability indicates that these challenges can be effectively managed through proper system architecture and robust implementation strategies.

The integration of battery and supercapacitor systems demonstrated synergistic benefits that exceed the capabilities of single-technology solutions. The reduction in battery cycling stress, evidenced by the improved round-trip efficiency of 89.7%, addresses a key limitation of battery-only systems [27]. The supercapacitor system's ability to handle high-frequency power fluctuations while maintaining rapid response capabilities throughout the evaluation period demonstrates the long-term viability of hybrid storage approaches for grid stability applications.

Several limitations of the current study warrant consideration. First, the six-month evaluation period, while sufficient for demonstrating system performance across seasonal variations, may not capture longer-term degradation effects in storage systems. Future studies should consider extended evaluation periods to assess long-term reliability and performance trends. Second, the specific renewable generation profile of the test site, dominated by solar PV, may not fully represent the challenges of different renewable mixes. Additional research is needed to validate system performance with different combinations of wind, solar, and other renewable sources.

The computational requirements of the machine learning algorithms, while manageable in the current implementation, may present scaling challenges in larger systems.

The study's focus on a single microgrid with specific storage capacities limits direct extrapolation to systems of significantly different scales. Future research should investigate the scalability of the proposed approach and potential optimizations for larger implementations. Additionally, the economic analysis, while comprehensive, was based on specific market conditions and rate structures. The generalizability of economic benefits to different market environments requires further investigation.

The reliance on high-frequency data collection (10kHz for power quality measurements) presents potential implementation challenges in resource-constrained environments. While essential for achieving the demonstrated performance improvements, this requirement may limit applicability in systems with less sophisticated monitoring capabilities. Future research could explore reduced data rate implementations that maintain acceptable performance levels while requiring less intensive monitoring infrastructure.

Though there are limitations, this study is enough to prove the potential of such hybrid storage systems, coupled with machine learning, in overcoming some challenges like those posed by renewable integration and grid stability. The achieved improvements in both technical and economic performance metrics provide a strong foundation for future development and implementation of advanced storage management systems. The successful integration of multiple storage technologies with sophisticated control algorithms demonstrates a viable path forward for increasing renewable penetration while maintaining grid stability and reliability.

CONCLUSION

By adapting hybrid energy storage systems with machine learning algorithms, this study proves an additional performance and a stability boost in renewable-rich microgrids. The implemented system achieved substantial improvements across multiple performance metrics, with the 27% enhancement in overall energy efficiency and 43% reduction in voltage fluctuations representing significant advancements in microgrid operation. The successful coordination of battery and supercapacitor technologies through a dual-layer control architecture establishes a viable framework for addressing the challenges of renewable intermittency while maintaining grid stability and reliability.

The achievement of 92% accuracy in renewable generation prediction, coupled with sophisticated storage management strategies, enabled proactive system optimization that yielded both technical and economic benefits. The 31% reduction in peak demand charges and 54.7% increase in energy arbitrage revenue demonstrate the practical viability of advanced storage management systems in commercial applications. These improvements, maintained consistently across seasonal variations, indicate the robustness and adaptability of the machine learning-enhanced control approach.

Future smart grid technologies and renewable energy adoption could have far-reaching consequences for the study. The demonstrated success in coordinating multiple storage technologies through machine learning algorithms provides a foundation for scaling renewable penetration while maintaining grid stability. The achieved improvements in system response times, power quality metrics, and economic performance establish new benchmarks for microgrid operation and control.

NOMENCLATURE

SOC_b	Battery SOC
SOC_{SC}	Supercapacitor SOC
P_d	Current power demand
$P_{r,f}$	Renewable generation forecast
t	Time of day
C_e	Electricity price signals
P_b	Battery power
P_{SC}	Supercapacitor power
R_{eff}	Energy efficiency
w	Weighting factor
$T(t)$	Temperature
$H(t)$	Humidity
$D(t)$	Day-type
P_{low}	low-frequency component
P_{high}	High-frequency component
$\sigma_P(t)$	Power variability

AUTHORSHIP CONTRIBUTIONS

Authors equally contributed to this work.

DATA AVAILABILITY STATEMENT

The authors confirm that the data that supports the findings of this study are available within the article. Raw data that support the finding of this study are available from the corresponding author, upon reasonable request.

CONFLICT OF INTEREST

The authors declared no potential conflicts of interest with respect to the research, authorship, and/or publication of this article.

ETHICS

There are no ethical issues with the publication of this manuscript.

REFERENCES

- [1] Hassan Q, Viktor P, Al-Musawi T, Ali BM, Algburi S, Alzoubi HM, et al. The renewable energy role in the global energy transformations. *Renew Energy Focus* 2024;48:100545. [\[CrossRef\]](#)
- [2] Khalid M. Smart grids and renewable energy systems: perspectives and grid integration challenges. *Energy Strategy Reviews* 2024;51:101299. [\[CrossRef\]](#)
- [3] Hussain MN, Kader KA, Ali MS, Ullah A, Dodaev AZ. An extensive analysis of the significance and difficulties of microgrids based on renewable energy in wireless sensor networks. *Control Syst Optimiz Lett* 2024;2:178–183. [\[CrossRef\]](#)
- [4] Tian X, An C, Chen Z. The role of clean energy in achieving decarbonization of electricity generation, transportation, and heating sectors by 2050: A meta-analysis review. *Renew Sustain Energy Reviews* 2023;182:113404. [\[CrossRef\]](#)
- [5] Ismail M, Alham MH, Ibrahim DK. A novel approach for optimal hybrid energy decarbonization using multi-criteria decision analysis: Abu Rudeis, Egypt as a case study. *Energy Convers Manag* 2023;290:117199. [\[CrossRef\]](#)
- [6] Emrani A, Berrada A. A comprehensive review on techno-economic assessment of hybrid energy storage systems integrated with renewable energy. *J Energy Storage* 2024;84:111010. [\[CrossRef\]](#)
- [7] Specht J, Madlener R. Deep reinforcement learning for the optimized operation of large amounts of distributed renewable energy assets. *Energy AI* 2023;11:100215. [\[CrossRef\]](#)
- [8] Elabbassi I, Khala M, Yanboiy EN, Eloutassi O, Hassouani YE. Evaluating and comparing machine learning approaches for effective decision making in renewable microgrid systems. *Result Eng* 2024;21:101888. [\[CrossRef\]](#)
- [9] Kazemtarghi A, Mallik A. Techno-economic microgrid design optimization considering fuel procurement cost and battery energy storage system lifetime analysis. *Electric Power Syst Research* 2024;235:110865. [\[CrossRef\]](#)
- [10] Rajkumar VS, Ştefanov A, Presekal A, Palensky P, Torres JLR. Cyber attacks on power grids: Causes and propagation of cascading failures. *IEEE Access* 2023;11:103154–103176. [\[CrossRef\]](#)
- [11] Rajkumar VS, Ştefanov A, Torres JLR, Palensky P. Dynamical analysis of power system cascading failures caused by cyber attacks. *IEEE Trans Industr Inform* 2024;20: 8807–8817. [\[CrossRef\]](#)
- [12] Ayubirad M, Qiu Z, Wang H, Weinkauff C, Van Nieuwstadt M, Ossareh HR et al. Model-based temperature tracking control in automotive fuel cells. *IEEE Power And Energy Conference At Illinois (PECI)*, April 2024. USA: IEEE; 2024. s.1–6. [\[CrossRef\]](#)
- [13] Hossain MB, Islam MR, Muttaqi KM, Sutanto D, Agalgaonkar AP. Advancement of fuel cells and electrolyzers technologies and their applications to renewable-rich power grids. *J Energy Storage* 2023;62:106842. [\[CrossRef\]](#)
- [14] Chandrasekaran K, Selvaraj J, Amaladoss CR, Veerapan L. Hybrid renewable energy based smart

- grid system for reactive power management and voltage profile enhancement using artificial neural network. *Energy Sources Part A: Recovery Utilization Environ Effect* 2021;43:2419–2442. [\[CrossRef\]](#)
- [15] Poulouse A, Kim S. Transient stability analysis and enhancement techniques of renewable-rich power grids. *Energies* 2023;16:2495. [\[CrossRef\]](#)
- [16] Machele IL, Onumanyi AJ, Abu-Mahfouz AM, Kurien AM. Interconnected smart transactive microgrids—A survey on trading, energy management systems, and optimisation approaches. *J Sensor Actuator Network* 2024;13:20. [\[CrossRef\]](#)
- [17] Kiasari M, Ghaffari M, Aly HH. A comprehensive review of the current status of smart grid technologies for renewable energies integration and future trends: The role of machine learning and energy storage systems. *Energies* 2024;17:4128. [\[CrossRef\]](#)
- [18] Alotaibi V, Abido MA, Khalid M, Savkin AV. A comprehensive review of recent advances in smart grids: A sustainable future with renewable energy resources. *Energies* 2020;13:1–41. [\[CrossRef\]](#)
- [19] Dawn S, Ramesh M, Ramakrishna A, Das SS, Rao KD, Islam MM et al. Integration of renewable energy in microgrids and smart grids in deregulated power systems: A comparative exploration. *Adv Energy Sustain Res* 2024;5:2400088. [\[CrossRef\]](#)
- [20] Gao X, Lin H, Jing D, Zhang X. Multi-Objective energy management of Solar-Powered integrated energy system under forecast uncertainty based on a novel Dual-Layer correction framework. *Solar Energy* 2024;281:112902. [\[CrossRef\]](#)
- [21] Hoang AT, Nguyen XP, Pham VV. Integrating renewable sources into energy system for smart city as a sagacious strategy towards clean and sustainable process. *J Clean Produc* 2021;305:127161. [\[CrossRef\]](#)
- [22] Adeyinka AM, Esan OC, Ijaola AO, Farayibi PK. Advancements in hybrid energy storage systems for enhancing renewable energy-to-grid integration. *Sustain Energy Res* 2024;11:1–23. [\[CrossRef\]](#)
- [23] Li P, Zhao Z, Li J, Liu Z, Liu Y, Sun Y, et al. Unlocking potential contribution of seasonal pumped storage to ensure the flexibility of power systems with high proportion of renewable energy sources. *Renew Energy* 2023;218:119280. [\[CrossRef\]](#)
- [24] Rashid SM. Employing advanced control, energy storage, and renewable technologies to enhance power system stability. *Energy Report* 2024;11:3202–3223. [\[CrossRef\]](#)
- [25] Zhao Q, Ali B, Kuwar M, Mishal A, Husam R, Mohsen A, et al. Conceptual design and optimization of integrating renewable energy sources with hydrogen energy storage capabilities. *Intern J Hydrogen Energy* 2024;79:1313–1330. [\[CrossRef\]](#)
- [26] Mellit A, Pavan AM, Lughi V. Deep learning neural networks for short-term photovoltaic power forecasting. *Renew Energy* 2021;172:276–288. [\[CrossRef\]](#)
- [27] Ali ZM, Calasan M, Aleem SHA, Jurado F, Gandoman FH. Applications of energy storage systems in enhancing energy management and access in microgrids: A review. *Energies* 2023;16:5930. [\[CrossRef\]](#)
- [28] Paşaoğlu A, Habibnezhad A. Strengthening a solar-wind-battery-diesel hybrid energy system by evaluating effective factors: An application of optimization method. *Nanotechnol Percept* 2024;21:26–44. [\[CrossRef\]](#)
- [29] Giraldo LF, Gaviria JF, Torres MI, Alonso C, Bressan M. Deep reinforcement learning using deep-Q-network for global maximum power point tracking: Design and experiments in real photovoltaic systems. *Heliyon* 2024;10:37974. [\[CrossRef\]](#)